# CERTIFICATE
## of Conformity

**Certificate No.:** GK 010095 001

**Test Report No.:** 37012331 001

**Certificate Holder:** **Pan-Italia Kft.**
2220 Vecsés, Üllői út 835, Hungary

**Manufacturer:** **73 PEPE SIHHI TESISAT MALZEMELERI IML. ITH. IHR. VE PAZ. LTD. STI.**
MERKEZ MAH. YILDIRIM BEYAZIT CAD. NO:2 MIMARSINAN B. CEKMECE ISTANBUL, TURKEY

**Product:** **Corrugated flexible metal hose assemblies (4602)**

**Identification:** **Models:**
**73 PEPE40BB ½″, PEPE40KB ½″,**
**PEPE60BB ½″, PEPE60KB ½″,**
**PEPE80BB ½″, PEPE80KB ½″,**
**PEPE100BB ½″, PEPE100KB ½″,**
**PEPE120BB ½″, PEPE120KB ½″,**
**PEPE150BB ½″, PEPE150KB ½″.**

See details in Annex I

**Tested according to:** **TS 10670:1993+T3:2009**

**Date of Validity:** **25.02.2029**

**This certificate refers to the above-mentioned product. This is to certify that the test sample is in conformity with the requirements stated above. This certificate does not imply assessment of the series-production of the product and does not permit the use of a CerTrust mark of conformity. The certificate is valid up to the date of validity provided that the test specifications and construction of the product remain unchanged during the period of validity.**

**Certification Body**

**Date of Issue:**

Budapest, 23.01.2025

.....
Gábor Tasnádi

CerTrust
dynamism, energetics, excellence

# Annex I to certificate No. GK 010095 001



| Models | Nominal length (mm) |
|---|---|
| 73 PEPE40BB ½", PEPE40KB ½", | 400 |
| PEPE60BB ½", PEPE60KB ½", | 600 |
| PEPE80BB ½", PEPE80KB ½", | 800 |
| PEPE100BB ½", PEPE100KB ½", | 1000 |
| PEPE120BB ½", PEPE120KB ½", | 1200 |
| PEPE150BB ½", PEPE150KB ½"* | 1500 |

*
B Internal thread
K External thread

Usability: 1, 2 and 3 gas families

Operational temperature range: (-20) – (+100) °C

Max. allowed pressure: 0.1 bar